

Borough of Fleetwood

PWSID #3060029

Annual Water Quality Report

Water Testing Performed in 2017

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater run-off and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater run-off and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to assure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

Information about Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Borough of Fleetwood is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Important Health Information:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as person with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

2017 Annual Drinking Water Quality Report of the Borough of Fleetwood

We are pleased to present to you this year's Annual Drinking Water Quality Report. We routinely monitor for constituents in your drinking water according to Federal and State Laws. The table shows the results of this monitoring for the period of January 1st to December 31st, 2017. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Water Drinking Act. The date has been noted on the sampling results table.

Our water source comes from 6 wells in Ruscombmanor Township, 1 well in Richmond Township, 2 wells in Fleetwood Borough, and 3 springs within the Willow Creek Watershed.

If you have any questions about this report or concerning your water utility, please contact our Water Commissioner, John Kesselring at the Borough office 610-944-8220. We want our valued customers to be informed about their water quality. If you want to learn more, please attend our regularly scheduled monthly meetings. They are held on the second Monday of every month at 6:30pm in the Community Center at 110 W. Arch Street, Fleetwood, PA.

CONTAMINANT (unit of measurement)	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Sample Date	Violation Y/N	Sources of Contamination
Chemical Contaminants							
Nitrate (ppm)	10	10	2.47	0-2.47	1/18/17	N	Runoff from fertilizer use
Fluoride (ppm)*	2	2	1.1	0.5-1.1	2/5/15	N	Water additive which promotes strong teeth
Haloacetic Acids (HAA5) (ppb)	60	n/a	5.2	0-10.4	8/16/17	N	Byproduct of drinking water disinfection.
Total Trihalomethanes (TTHMs) (ppb)	80	n/a	19.70	3.68-35.8	8/16/17	N	Byproduct of drinking water chlorination
Chlorine (ppm)	4	4	1.4	0.76-1.4	3/2017	N	Water additive used to control microbes

*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

Entry Point Disinfectant Residual

Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Sample Date	Violation Y/N	Sources of Contamination
Chlorine EP 101 (ppm)	0.4	0.38	0.38-1.51	2017	N	Water additive used to control microbes.
Chlorine EP 103 (ppm)	0.4	0.4	0.4-1.57	2017	N	Water additive used to control microbes.
Chlorine EP 104 (ppm)	0.4	0.5	0.5-1.91	2017	N	Water additive used to control microbes.

Lead and Copper

Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	# of Sites above AL of Total Sites	Sample Date	Violation Y/N	Sources of Contamination
Copper* (ppm)	1.3	1.3	0.288	0 out of 20	2016	N	Corrosion of household plumbing
Lead* (ppb)	15	0	1	1 of 20	2016	N	Corrosion of household plumbing

Other Violations: See the attached

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected; however the DEP has determined that your water IS SAFE at these levels. The PA Department of Environmental Protection allows the Authority to test for some contaminants less often than annually because the concentrations of these contaminants do not change frequently. Therefore, some of our data, though representative, is not from 2017.

In our continuing efforts to maintain a dependable water supply, it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

We at The Borough of Fleetwood work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources. Please check out our website at www.fleetwoodboro.com for additional information about the Borough.

What's In My Water?

In the summary table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms and abbreviations we've provided you with the following definitions:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.

Level 1 Assessment - A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment - A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.


Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter ($\mu\text{g/L}$) **ppq** = parts per quadrillion, or picograms per liter

ppm = parts per million, or milligrams per liter (mg/L) **ppt** = parts per trillion, or nanograms per liter

WATER CONSERVATION FOR KIDS



When brushing your teeth or washing hands, don't leave the water running! Turn off faucets tightly.

When you give your pet fresh water, don't throw the old water down the drain, use it to water your trees and shrubs.



Use the sprinkler in an area where your lawn needs water.

Take a quick shower! A shower uses 10 – 25 gallons of water compared to as many as 70 gallons for a bath!

Throw your leftover ice cubes from your drinks into the house plants to save on watering them.



WHAT IS YOUR WATER FOOTPRINT?

The amount of water you use is known as your water footprint and is the best way to see where you can start saving on water in your home. Figure out how much water you use and how you can figure out how to use less at:

http://www.savewaterpa.org/calculate_your_water_footprint

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Fleetwood Borough Water System

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the months of April and May of 2017 we collected all samples on time and they were within limit, however results were reported late (see attached DEP Violation Report). _____ and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for chlorine _____ and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Chlorine	April 2017	5	Collected on required date	Reported 1 day late
Chlorine	May 2017	5	Collected on required date	Reported 1 day late

What happened? What was done?

All chlorine samples for both months were taken properly & passed. However, results were not reported until after the 10th on both months. _____

For more information, please contact John Kesselring _____ at (610) 944-8220 _____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you Fleetwood Borough _____.